

## **APPENDIX A**

### **Non-Federally Regulated PCB-Containing Building Materials Scope of Work**

The location of those materials classified as Excluded PCB Products with total PCB concentrations  $\geq 1$  PPM and  $< 50$  PPM based upon sample results of homogeneous material are shown on Diagram PCB-01B and sample results for the caulking and/or glazing compounds are found in Table 1.

All caulking and/or glazing compounds containing  $\geq 1$  PPM and  $< 50$  PPM shall be removed without the removal of associated adjacent porous building substrates to start utilizing the same engineering controls described for interior and exterior removals within this document. Following the removal of these caulking and/or glazing compounds; the following actions will be performed:

- Verification samples of adjacent porous building materials substrates will be collected at a frequency of 1 per every 50 linear feet of homogenous caulk or glazing removed.
- If the verification sample is  $< 1$  PPM then no further action will be performed.
- If the verification sample is  $\geq 1$  PPM then one of the following two actions will be performed:
  - Six-inches of building materials will be removed from either side of the caulk for areas that are within the demolition/renovation area of the project.
  - Building materials will be encapsulated using materials and procedures that conform to the attachment included in this appendix.